Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 24/12/2018**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 19-12-18

Customer ID : Second Floor Chejja Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 24/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Second Floor Chejja Concrete	M20	17/12/2018	24/12/2018	150.81 X 151.97 X 150.40	22918	**8.929**	431.5	18.8	18.6
2	Second Floor Chejja Concrete	M20	17/12/2018	24/12/2018	149.45 X 149.56 X 151.27	22352	**8.454**	409.4	18.3	
3	Second Floor Chejja Concrete	M20	17/12/2018	24/12/2018	150.03 X 151.56 X 151.55	22739	**8.689**	426.6	18.8	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 14/01/2019**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 19-12-18

Customer ID : Second Floor Chejja Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 14/01/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Second Floor Chejja Concrete	M20	17/12/2018	14/01/2019	151.76 X 151.95 X 150.08	23060	**8.973**	533.9	23.2	23.2
2	Second Floor Chejja Concrete	M20	17/12/2018	14/01/2019	149.57 X 151.50 X 149.99	22659	**8.108**	517.5	22.8	
3	Second Floor Chejja Concrete	M20	17/12/2018	14/01/2019	151.14 X 151.60 X 149.86	22912	**8.574**	539.2	23.5	

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL Pro Sig Date BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 09/11/2018**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 05-11-18

Customer ID : First Floor Chejja Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 09/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	First Floor Chejja Concrete	M20	02/11/2018	09/11/2018	151.94 X 150.55 X 149.51	22875	**8.929**	418.1	18.3	18.3
2	First Floor Chejja Concrete	M20	02/11/2018	09/11/2018	150.28 X 151.23 X 151.00	22726	**8.454**	415.9	18.3	
3	First Floor Chejja Concrete	M20	02/11/2018	09/11/2018	150.81 X 150.44 X 151.64	22688	**8.689**	417.8	18.4	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 30/11/2018**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 05-11-18

Customer ID : First Foor Chejja Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 30/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	First Foor Chejja Concrete	M20	02/11/2018	30/11/2018	150.06 X 151.60 X 151.17	22750	**8.973**	541.0	23.8	23.5
2	First Foor Chejja Concrete	M20	02/11/2018	30/11/2018	149.21 X 152.00 X 151.27	22679	**8.108**	519.1	22.9	
3	First Foor Chejja Concrete	M20	02/11/2018	30/11/2018	151.29 X 151.88 X 151.65	22977	**8.574**	546.8	23.8	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R RUDRAPRASAD
Authorized Signatory
Technical Manager

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 09/11/2018**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 05-11-18

Customer ID : First Floor Chejja Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 09/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	First Floor Chejja Concrete	M20	02/11/2018	09/11/2018	149.13 X 150.62 X 149.80	22463	**8.929**	417.5	18.6	18.7
2	First Floor Chejja Concrete	M20	02/11/2018	09/11/2018	149.68 X 149.32 X 151.06	22351	**8.454**	419.7	18.8	
3	First Floor Chejja Concrete	M20	02/11/2018	09/11/2018	151.79 X 150.06 X 150.05	22778	**8.689**	423.4	18.6	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 09/11/2018**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 05-11-18

Customer ID : First Floor Chejja Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 09/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	First Floor Chejja Concrete	M20	02/11/2018	09/11/2018	149.13 X 150.62 X 149.80	22463	**8.929**	417.5	18.6	18.7
2	First Floor Chejja Concrete	M20	02/11/2018	09/11/2018	149.68 X 149.32 X 151.06	22351	**8.454**	419.7	18.8	
3	First Floor Chejja Concrete	M20	02/11/2018	09/11/2018	151.79 X 150.06 X 150.05	22778	**8.689**	423.4	18.6	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 30/11/2018

Lab ID : **CP-2019-01-25-92**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 05-11-18

Customer ID : First Foor Chejja Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 30/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	First Foor Chejja Concrete	M20	02/11/2018	30/11/2018	149.40 X 151.57 X 151.17	22645	**8.187**	537.4	23.7	23.2
2	First Foor Chejja Concrete	M20	02/11/2018	30/11/2018	149.10 X 149.13 X 151.15	22236	**8.348**	491.9	22.1	
3	First Foor Chejja Concrete	M20	02/11/2018	30/11/2018	151.43 X 151.41 X 149.53	22927	**8.911**	546.4	23.8	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 24/12/2018**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 19-12-18

Customer ID : Secound Floor Lintel Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 24/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Secound Floor Lintel Concrete	M25	17/12/2018	24/12/2018	151.01 X 149.04 X 150.78	22507	**8.398**	534.2	23.7	22.8
2	Secound Floor Lintel Concrete	M25	17/12/2018	24/12/2018	150.95 X 149.46 X 150.22	22561	**8.861**	501.9	22.2	
3	Secound Floor Lintel Concrete	M25	17/12/2018	24/12/2018	150.94 X 149.42 X 150.40	22553	**8.224**	508.7	22.6	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 14/01/2019**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 19-12-18

Customer ID : Secound Floor Lintel Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 14/01/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Secound Floor Lintel Concrete	M25	17/12/2018	14/01/2019	149.28 X 151.26 X 149.02	22580	**8.539**	628.7	27.8	27.8
2	Secound Floor Lintel Concrete	M25	17/12/2018	14/01/2019	149.96 X 151.69 X 149.11	22748	**8.185**	605.9	26.6	
3	Secound Floor Lintel Concrete	M25	17/12/2018	14/01/2019	150.15 X 150.83 X 151.92	22647	**8.369**	656.4	29.0	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 02/01/2019**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 28-12-18

Customer ID : Secound Floor Roof Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 02/01/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Secound Floor Roof Concrete	M25	26/12/2018	02/01/2019	149.52 X 150.12 X 151.28	22447	**8.398**	531.1	23.7	23.0
2	Secound Floor Roof Concrete	M25	26/12/2018	02/01/2019	149.10 X 150.13 X 151.99	22384	**8.861**	506.3	22.6	
3	Secound Floor Roof Concrete	M25	26/12/2018	02/01/2019	150.47 X 149.43 X 149.88	22483	**8.224**	513.9	22.9	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R. Rudraprasad

CIVIL Pro Sig..... Date..... BANGALORE

R RUDRAPRASAD
Authorized Signatory
Technical Manager

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 23/01/2019**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 28-12-18

Customer ID : Secound Floor Roof Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 23/01/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Secound Floor Roof Concrete	M25	26/12/2018	23/01/2019	149.18 X 150.38 X 151.10	22433	**8.539**	612.3	27.3	27.6
2	Secound Floor Roof Concrete	M25	26/12/2018	23/01/2019	151.35 X 150.39 X 149.27	22761	**8.185**	605.7	26.6	
3	Secound Floor Roof Concrete	M25	26/12/2018	23/01/2019	151.17 X 149.02 X 150.63	22527	**8.369**	651.4	28.9	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 02/01/2019**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 28-12-18

Customer ID : Secound Floor Roof Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 02/01/2019

SL No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Secound Floor Roof Concrete	M25	26/12/2018	02/01/2019	150.07 X 151.34 X 150.20	22712	**8.398**	539.2	23.7	22.9
2	Secound Floor Roof Concrete	M25	26/12/2018	02/01/2019	149.68 X 150.56 X 150.25	22536	**8.861**	511.9	22.7	
3	Secound Floor Roof Concrete	M25	26/12/2018	02/01/2019	149.47 X 149.99 X 150.99	22419	**8.224**	500.0	22.3	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL Pro BANGALORE Sig Date

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 23/01/2019**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 28-12-18

Customer ID : Secound Floor Roof Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 23/01/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Secound Floor Roof Concrete	M25	26/12/2018	23/01/2019	150.39 X 151.65 X 150.10	22807	**8.539**	622.6	27.3	27.3
2	Secound Floor Roof Concrete	M25	26/12/2018	23/01/2019	149.74 X 150.89 X 151.42	22594	**8.185**	595.8	26.4	
3	Secound Floor Roof Concrete	M25	26/12/2018	23/01/2019	151.24 X 150.74 X 150.89	22797	**8.369**	645.4	28.3	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 02/01/2019**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 28-12-18

Customer ID : Secound Floor Roof Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 02/01/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Secound Floor Roof Concrete	M25	26/12/2018	02/01/2019	149.08 X 150.53 X 149.64	22441	**8.398**	527.4	23.5	22.8
2	Secound Floor Roof Concrete	M25	26/12/2018	02/01/2019	150.97 X 149.39 X 149.37	22554	**8.861**	513.4	22.8	
3	Secound Floor Roof Concrete	M25	26/12/2018	02/01/2019	149.39 X 151.32 X 149.02	22606	**8.224**	498.5	22.1	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL PRO Sig. Date BANGALORE

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-01-25-92** **Date: 23/01/2019**

Project Name : Construction of Marrige Community Hall Chikkabettahalli Village in Ward No 03 of Yelahanka Assembly Constitutency.

Agency : Sri.H.V Omkarappa, Class-1 PWD Contractor,#27, Taralabalu Enclave, Near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE/(Project)/Ynk/WO/119/2017-18

Date of Receipt : 28-12-18

Customer ID : Secound Floor Roof Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 23/01/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Secound Floor Roof Concrete	M25	26/12/2018	23/01/2019	151.14 X 149.04 X 150.33	22526	**8.539**	613.5	27.2	27.5
2	Secound Floor Roof Concrete	M25	26/12/2018	23/01/2019	150.37 X 151.84 X 151.36	22832	**8.185**	608.2	26.6	
3	Secound Floor Roof Concrete	M25	26/12/2018	23/01/2019	149.73 X 149.10 X 151.87	22324	**8.369**	636.3	28.5	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL PRO BANGALORE Sig. Date

Page 1/1
****End of Report****